

Mike Ruff Music

PAT Tests											
Test No.	Equipment Description	Serial No.	Class	Visual inspect	Continuity	Earth Bond	Insulation	Pass Fail	Tested by	Retest due	Notes
MR001	Denon CD recorder DCD685	2094553282	2	✓	✓	/	∞	Pass	CAH	Oct 2014	1
MR002	Mains lead for above fig 8 connector	none	1	✓	✓	<0.02Ω	∞	Pass	CAH	Oct 2014	
MR003	Berringer Eurorack MX2642A Mixer	81087612	2	✓	✓	/	∞	Pass	CAH	Oct 2014	2
MR004	Greenbank Studios Monitor Wedge	none	1	✓	✓	<0.01Ω	∞	Pass	CAH	Oct 2014	3
MR005	13 A 4 way 1 metres	none	1	✓	✓	<0.02Ω	∞	Pass	CAH	Oct 2014	
MR006	13 A 4 way 5 metres	none	1	✓	✓	<0.02Ω	∞	Pass	CAH	Oct 2014	
MR007	Wicks mains extn drum 2 way 6metres	none	1	✓	✓	<0.02Ω	∞	Pass	CAH	Oct 2014	
MR008	Mains extn drum 2 way 6metres	none	1	✓	✓	<0.01Ω	∞	Pass	CAH	Oct 2014	
MR009	IEC mains lead 2 metres	none	1	✓	✓	<0.01Ω	∞	Pass	CAH	Oct 2014	
MR010	IEC mains lead 2 metres	none	1	✓	✓	<0.01Ω	∞	Pass	CAH	Oct 2014	
MR011	IEC mains lead 2 metres	none	1	✓	✓	<0.01Ω	∞	Pass	CAH	Oct 2014	
MR012	Greenbank Studios Mixer Amp	GB00274	1	✓	✓	<0.05Ω	∞	Pass	CAH	Oct 2014	IEC mains lead
MR013	Phonic MAR4 Power Amp	AACB4006	1	✓	✓	<0.1Ω	∞	Pass	CAH	Oct 2014	fixed mains lead
MR014	Sony CFD828L CD player	none	2	✓	✓	/	∞	Pass	CAH	Oct 2014	1
	Equipment tested 4/10/12										

Notes

1. Separate Fig 8 mains lead
2. Separate power unit - double insulated
3. Separate IEC mains lead, Wooden construction no exposed metal parts